

Er. D. NATARAJAN, B.E.(CIVIL),M.I.E.,
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS 1A, THIRUVANNAMALAI DISTRICT
TVMalai Collector, Reg. No. **ந.க.டி. 321824/2012** dated 03.01.2013

Res: 30-A, 3rd Street, S.S.Nagar,
Palanipet, Arakkonam - 631002
Off: 400, Nathaji Bose 4th Street,
Phase III, TNHB, Sathuvachari
Vellore - 632 009

Cell: 9443106470, 8056631312, 9788026626
Email: dnatarajan8@gmail.com

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL
STATEMENT ACCOMPANYING FORM - A

1. Name of the School and Door no of the Building : **SKP VANITHA INTERNATIONAL SCHOOL**
(Sponsored by Sri S. Kuppaswamy Memorial Educational Trust)
Chengam Road, Chinnakangeyanur Village,
Tiruvannamalai Taluk & District - 606 611
2. Location (street No, Ward No, Name of place, i.e., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S. F. No. 10/5,
Chengam Road, Chinnakangeyanur Village,
Tiruvannamalai Taluk,
Tiruvannamalai District - 606 611
3. Year of construction : **Ground & First Floor: RCC: 2011**
Second Floor: RCC: 2012
4. Approximates cost of construction as per current rate : Rs. 620.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational
6. Purpose for which the building has hitherto been used : Educational
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under:
(i) Foundation : RCC Column & Isolated Footing
(ii) Basement : RCC Column, Plinth Beam & Brick in CM
(iii) Superstructure : RCC Column & Brick in CM
(iv) Floor & Roof are to be given) : Flooring: Vitrified Tiles, Marble & Cement
Roof: RCC Slab
8. Period for which the license is require : May be issued from **01.06.2019 to 31.05.2022**
(For Three years only)
9. Number of persons to be accommodated Refer "ANNEXURE" to this : **Eight Hundred Forty (840) Pupils only**

Place : Vellore

Date : 01.06.2019

Signature of the Chairman


Signature of the Engineer
Er. D. NATARAJAN, B.E. (CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Tiruvannamalai District
#400, Nathaji Bose 4th Street,
Phase III, TNHB, Sathuvachari
Vellore - 632 009.
Cell 94431 06470, 8056631312



ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made, I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the College premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.

Signature of the Chairman

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
CHARTERED ENGINEER
REGISTERED&APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS 1A, THIRUVANNAMALAI DISTRICT

Res: 50-A,3rd Street, S.S.Nagar,
Palanipet, Arakkonam - 631002
Off: 400, Nethaji Bose 4th Street
Phase III, TNHB, Sathuvachari
Vellore - 632 009
Cell: 9443106470, 8056631312, 9789026626
Email: dnatarajan8@gmail.com

FORM - B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

SKP VANITHA INTERNATIONAL SCHOOL, CHINNAKANGEYANUR VILLAGE

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. Foundation:

- | | | |
|------|--|-------------------|
| i. | Depth below ground level | : 08ft below G.L |
| ii. | Nature of soil met out in the foundation | : Hard Gravel |
| iii. | Pressure at foundation | : 11 tones / Sq.m |
| iv. | Probable safe bearing capacity of the foundation | : 21 tones / Sq.m |

2. Superstructure:

- | | | |
|-----|--|---|
| i. | Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 35 Kg / Sq. cm
b) Masonry : 08 tones / Sq.m. |
| ii. | Nature of masonry and concrete And its safe permissible stress | : Brick masonry in cm: 30 tones / Sq.m.
R.C.C : 40 Kg / Sq.cm. |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper Toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.06.2019 to 31.05.2022.

Signature of the Chairman


Signature of the Engineer
E. D. NATARAJAN, B.E. (CIVIL) M.I.E.
Chartered Engineer
Panel Engineer Class 1A
Thiruvannamalai District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachari
Vellore - 632 009.
Cell: 94431 06470, 80430 00341

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
 CHARTERED ENGINEER
 REGISTERED&APPROVED ENGINEER
 BY THE BOARD OF ENGINEERS, TAMIL NADU,
 PANEL ENGINEER CLASS 1A, THIRUVANNAMALAI DISTRICT

Res: 50-A,3rd Street, S.S.Nagar,
 Palanipet, Arakkonam - 631002
 Off: 400, Nethaji Bose 4th Street
 Phase III, TNHB, Sathuvachari
 Vellore - 632 009
 Cell: 9443106470, 8056631312, 9788026626
 Email: dnatarajan8@gmail.com

FORM - C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

SKP VANITHA INTERNATIONAL SCHOOL, CHINNAKANGEYANUR VILLAGE

Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No, street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
SKP VANITHA INTERNATIONAL SCHOOL (Sponsored by Sri S. Kuppaswamy Memorial Educational Trust) Chengam Road, Chinnakangeyanur Village, Tiruvannamalai Taluk, Tiruvannamalai District - 606 611	Ground & First Floor: RCC: 08 Yrs Second Floor: RCC: 07 Yrs	Rs. 620.00 Lakhs	Ground Floor +2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational	License may be issued for the period of Three Years from 01.06.2019 to 31.05.2022	840 Pupils only	Building is structurally sound

Signature of the Chairman


 Signature of the Engineer, Civil, MIE
 Chartered Engineer
 Panel Engineer Class 1A
 Tiruvannamalai District
 #400, Nethaji Bose 4th Street,
 Phase III, TNHB, Sathuvachary
 Vellore - 632 009
 Cell: 94431 06470, 99430 09341